

凯威GFW系列钢结构接闪带塔基础选型表

基本风压 (KN/m ²)	总高度 H(米)	编号	修正后的地基承载力KN/m ²			根开L (m)	带塔跨度 (m)	基础形式 编号	基础尺寸m		基础混凝土体 积m ³	重量KG
			100	150	200				H	b		
0.4	20	GFW1-1	√			1.500	40~80	JA-4	2.4	3.2	13.788	1275.3
		GFW1-2		√		1.500	40~80	JB-1	2.4	1.2	6.880	1275.3
	25	GFW1-3	√			1.800	40~120	JA-7	2.4	3.6	16.972	1701.6
		GFW1-4		√		1.800	40~120	JB-5	2.4	1.5	10.368	1701.6
	30	GFW1-5		√		2.100	40~160	JB-11	2.9	1.8	18.700	2218.7
		GFW1-6			√	2.100	40~160	JB-7	2.9	1.5	13.140	2218.7
	35	GFW1-7		√		2.400	60~160	JB-13	2.9	1.8	18.700	2845.1
		GFW1-8			√	2.400	60~160	JB-9	2.9	1.5	13.140	2845.1
	40	GFW1-9		√		2.700	80~200	JB-14	2.9	1.8	18.700	3747.9
		GFW1-10			√	2.700	80~200	JB-10	2.9	1.5	13.140	3747.9
0.7	20	GFW2-1	√			1.500	40~80	JA-6	2.4	3.6	16.972	1333.2
		GFW2-2		√		1.500	40~80	JA-6	2.4	3.6	16.972	1333.2
	25	GFW2-3	√			1.800	40~120	JA-8	2.4	4	21.372	1864.9
		GFW2-4		√		1.800	40~120	JB-5	2.4	1.5	13.788	1864.9
	30	GFW2-5		√		2.100	40~160	JB-11	2.9	1.8	18.700	2390.6
		GFW2-6			√	2.100	40~160	JB-7	2.9	1.5	13.140	2390.6
	35	GFW2-7		√		2.400	60~160	JB-15	2.9	2.2	27.020	3169.8
		GFW2-8			√	2.400	60~160	JB-13	2.9	1.8	18.700	3169.8
	40	GFW2-9		√		2.700	80~200	JB-16	2.9	2.2	27.020	4234.3
		GFW2-10			√	2.700	80~200	JB-16	2.9	2.2	27.020	4234.3